

NOT USED3
NOT TO SCALEE-102

CONDUIT ROUGH-IN DETAIL2
NOT TO SCALEE-102

PULL STRING/WIRE. TEMPORALLY TIE STRING OFF TO STRUCTURE FOR FUTURE CABLE VENDOR.

1/2" CONDUIT. ANCHOR TO STUD/FRAMING MEMBER WITH CONDUIT CLAMP. STUB UP TO A MINIMUM OF 6" ABOVE ADJACENT CEILING - U.N.O.

STUB CONDUIT THROUGH EXTERIOR WALL. END OF CONDUIT TO BE FLUSH WITH ARCHITECTURAL FINISH. CONDUIT STUB ONLY - DO NOT PROVIDE JUNCTION BOX ON EXTERIOR OF BUILDING.

REFER PLAN

SECURITY CAMERA PLAN1
Scale= 1/4" = 1'-0"E-102

PANDA EXPRESS, INC.
1683 Walnut Grove Ave.
Rosemead, California 91770
Telephone: 626.799.9898
Facsimile: 626.372.8288

All ideas, designs, arrangement and plans indicated or represented by this drawing are the property of Panda Express Inc. and were created for use on this specific project. None of these ideas, designs, arrangements or plans may be used by or disclosed to any person, firm, or corporation without the written permission of Panda Express Inc.

REVISIONS:

1	CHECK SET	12-15-20
2	PERMIT SET	12-18-20
3	BID SET	02-01-21
4	CONSTRUCTION SET	07-08-21

ISSUE DATE:

1	CHECK SET	12-15-20
2	PERMIT SET	12-18-20
3	BID SET	02-01-21
4	CONSTRUCTION SET	07-08-21

DRAWN BY: KTF

PANDA PROJECT #: S8-21-D8043
ARCH PROJECT #: P7356.2

Plans Prepared By
CPH, Inc.
500 West Fulton St.
Sanford, FL 32771
Ph: 407.322.6841
Licenses:
Eng. C.O.A. No. 3215
Survey L.S. No. 7143
Arch. Lic. No. AA260926
Lndscp. Lic. No. LC000298

**A Full Service
A & E Firm**

PANDA EXPRESS
TRUE WARM & WELCOME 2300
2599 S WOODLAND BLVD
DELAND, FL 32720

E-102
SECURITY CAMERA PLAN
TRUE WARM & WELCOME 2300 R1